

OHA Drinking Water Services Water Advisory Details

PWS ID: OR41 [00290](#)

PWS Name: STAFFORDSHIRE WATER SYSTEM

Advisory Type: Boil Water

Reason: Loss of Pressure

Area Affected: Partial - All houses on Chelsea Ln and Devonshire Dr

Affected Populations: All

Begin Date: May 28, 2024

Date Lifted: *Open*

Contacted By: ALVIANI, NICHOLAS (LANE COUNTY EHS)

Who Was Contacted: Garren Friedemann

Contact Phone: 541-505-9968

Details: Phone contact from operator regarding break in ball valve from one well effecting All houses on Chelsea Ln and Devonshire Dr. The system has repaired the valve and will sample for bacteria on 5/29.